

PETROLEUM BULK STORAGE REGISTRATION CERTIFICATE



(315) 793-2555

TANK NUMBER	TESTING DUE DATE	DATE LAST TESTED	TANK TYPE	CAPACITY	DATE INSTALLED	FEE PAID
001	12/87		BARE STEEL	4,000	05/71	150
002			BARE STEEL	1,000	05/71	

\* Aboveground tanks require monthly visual inspections and documented internal inspections every ten years as described in 6 NYCRR Part 613.

As authorized representative of the above named facility, I affirm under penalty of perjury that the information displayed on this form is correct to the best of my knowledge. Additionally, I recognize that I am responsible for assuring that this facility is in compliance with all sections of 6 NYCRR Parts 612, 613 and 614, not just those cited below:

- The facility must be reregistered if there is a transfer of ownership.
- The Department must be notified within 30 days prior to adding, replacing, reconditioning, or permanently closing a stationary tank.
- The facility must be operated in accordance with the Code for Storing Petroleum, 6 NYCRR Part 613.
- Any new facility or substantially modified facility must comply with the Code for New and Substantially Modified Facilities, 6 NYCRR Part 614.
- This certificate must be displayed on the premises at all times.

\_\_\_\_\_  
 Signature of Representative/Owner

\_\_\_\_\_  
 Date

ISSUED BY: <b>COMMISSIONER THOMAS C. JORLING</b>		OPERATOR <b>ED SALAMACHA MAIN ST. HAMMOND NY</b>	
PETROLEUM BULK STORAGE ID NUMBER <b>461830</b>		<b>13646</b>	
DATE ISSUED <b>12/06/88</b>	EXPIRATION DATE <b>12/06/93</b>		
FACILITY <b>HAMMOND ENTERPRISES MAIN STREET HAMMOND NY</b>		OWNER <b>ED SALAMACHA MAIN STREET HAMMOND NY</b>	
<b>13646</b>		<b>13646</b>	
EMERGENCY CONTACT: <b>ED SALAMACHA MAIN ST. HAMMOND NY 13646 (315) 324-5191</b>			

DEPARTMENT COPY

S

RECEIVED

DEC 13 1988

MYS Dept. Environmental Conservation  
REGIONAL OFFICE  
REGIONAL ENGINEER

